

Certificate of Compliance

Subject: 4 & 8 mil Black Polyethylene FR (Also Known as Blown Black)

<u>Description:</u> 4 and 8 mil Black Polyethylene FR UVI A polyethylene based formulation with fire retardant additives and UV inhibitors. The color is black. This film is opaque and slightly embossed.

4 mil and 8 mil Black Polyethylene FR has been certified to pass the following fire retardant standards by independent certified laboratories: NFPA 701-99 Test 1 NFPA 701-2004 Test 1 ASTM E 84-01

4 mil and 8 mil Black Polyethylene FR has been certified to pass the following specification:

BAC5034-2 and PSD 6-30

Shelf life: 18 months if stored indoors

It is hereby certified that each lot of the above described materials are made using the same formulation as that used to pass the fire retardant tests listed above.

Zevan Riedel

Tevan Riedel President Americover Inc.



CALIFORNIA DEPARTMENT OF FORESTRY and FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

REGISTERED FLAME RESISTANT PRODUCT

Product:

4 MIL BLACK FR PLASTIC

Registration No. F-57501

Product Marketed By: AMERICOVER INC. 2067 WINERIDGE PL., SUITE F ESCONDIDO, CA 92029

This product meets the minimum requirements of flame resistance established by the California State Fire Marshal for products identified in Section 13115, California Health and Safety Code.

The scope of the approved use of this product is provided in the current edition of the CALIFORNIA APPROVED LIST OF FLAME RETARDANT CHEMICALS AND FABRICS, GENERAL AND LIMITED APPLICATIONS CONCERNS published by the California State Fire Marshal.

Deputy State Fire Marshal

Expire: 6/30/2015



CLIENT: AMERICOVER, INC. 2067 Wineridge Pl., Ste. F Escondido, CA 92029 Teven Riedel

	Test Report No: 58709	00 Date: April 13, 2006
-		
SAMPLE ID:		The Client submitted and identified the following test material as 4 mil Polyethylene Film, Black.
DATE OF RECEIPT:		Entered into SGS USTC sample tracking system on March 31, 2006.
TESTING PERIOD:		April 13, 2006.
AUTHORIZATION:		Testing authorized by Teven Riedel.
TEST REQUESTED:		The sample material was tested in accordance with the procedures outlined in NFPA 701 Fire Test Method 1 (small scale) 2004 Edition "Standard Methods of Fire Tests for Flame-Resistant Textiles and Films".
TEST RESULTS:		Pass. See page 2 for detailed results. See Performance Criteria on page 2.

Tested by

alin

Brian Ortega Test Technician

Signed for and on behalf of SGS U.S. Testing Company Inc.

12-12

Greg Banasky Supervisor Fire Technology

Page 1 of 2

This report is issued by SGS U.S. Testing Company Inc. under its General Conditions for Testing Services (copy available on request). SGS U.S. Testing's responsibility under this report is limited to proven negligence and will in no case be more than the amount of the testing fees. Except by special arrangement, samples are not retained by SGS U.S. Testing for more than 3Q days. The results shown on this test report refer only to the sample(s) tested unless otherwise stated, under the conditions agreed upon. Anyone relying on this report should understand all of the details of the engagement. Neither the name, seals, marks nor insignia of SOS U.S. Testing may be used in any advertising or promotional materials without the prior written approval of SGS U.S. Testing. The test report cannot be reproduced, except in full, without prior written permission of SOS U.S. Testing Company Inc.

SGS U.S. Testing Company, Inc.

Consumer Testing Services: 8385 White Oak Avenue, Rancho Cucamonga, CA 91730 t (909) 483-0250 f (909) 483-0336 wwwsgs.com



CLIENT: AMERICOVER, INC.

TEST RESULTS: 4 mil Polyethylene Film, Black


Specimen No.	Initial Weight, g.	Final Weight, g.	Weight Loss, g.	Percent Weight Loss	Time of Flaming of pieces on floor (seconds)			
1	5.8	5.0	0.8	13.8	0			
2	5.5	5.3	0.2	3.6	0			
3	5.5	5.4	0.1	1.8	0			
4	5.6	5.1	0.5	8.9	0			
5	5.8	5.7	0.1	1.7	0			
6	5.9	5.7	0.2	3.4	0			
7	5.5	5.3	0.2	3.6	0			
8	5.7	5.2	0.5	8.8	0			
9	5.7	5.1	0.6	10.5	0			
10	5.5	5.3	0.2	3.6	0			
6.0 Av	Average Percent Weight Loss							
4.0 Sta	Standard Deviation							
0 Av	Average Time of Flaming of Pieces on the Floor (seconds)							

PERFORMANCE CRITERIA

1)Where fragments or residues of specimens that fall to the floor of the test chamber continue to burn for more than an average of 2 seconds per specimen for the sample of 10 specimens, the material shall be recorded as failing the test.

2)Where the average weight loss of the 10 specimens in a sample is greater than 40 percent, the material shall be recorded as failing the test.





TEST RESULTS:

Flame Spread

Smoke Density

40

10 For detailed results see page 3.

Tested by

Brian Ortega

Test Technician

Signed for and on behalf of SGS U.S. Testing Company Inc. SGS - SGS - SGS - SGS

SGS . SGS

SGS • SGS • SGS • SGS • SGS • SGS

Greg Banasky

Supervisor Fire Technology

Page 1 of 4

This report is issued by SGS U.S. Testing Company Inc. under its General Conditions for Testing Services (copy available upon request). SGS U.S. Testing's responsibility under this report is limited to proven negligence and will in no case be more than the amount of the testing fees. Except by special arrangement, samples are not retained by SGS U.S. Testing for more than 30 days. The results shown on this test report refer only to the sample(s) tested unless otherwise stated, under the conditions agreed upon. Anyone relying on this report should understand all of the details of the engagement. Neither the name, seals, marks nor insignia of SGS U.S. Testing may be used in any advertising or promotional materials without the prior written approval of SGS U.S. Testing. The test report cannot be reproduced, except in full, without prior written permission of SGS U.S. Testing Company Inc.

Member of the SGS Group (Société Générale de Surveillance)





CLIENT: AMERICOVER, INC.

Report No.: 174451-2 Date: February 25, 2003 Page: 2 of 4

PREPARATION AND CONDITIONING: The sample was submitted in two pieces 24" wide by 12' long, conforming to chamber dimensions. The sample was supported during testing by 2" hexagonal mesh poultry netting running the length of the test chamber and 1/4" round metal rods placed at two foot intervals across the width of the test chamber.

Prior to testing, the specimen was placed in the conditioning room (maintained at 73.4 $\pm\,5^\circ$ F and a relative humidity of 50 \pm 5%) and allowed to reach moisture equilibrium.

SUMMARY OF ASTM E84 RESULTS: Because of the possible variations in reproducibility, the results are adjusted to the nearest figure divisible by 5.

SAMPLE	FLAME SPRE AD	SMOKE DENSITY
Black 4 mil FR Film	10	40
an and a subsection		

In order to obtain the Flame Spread Classification, the above results should be compared to the following table:

NFPA CLASS	UBC CLASS	FLAME SPREAD		
A	.	0 through 25		
B	11	26 through 75		
С	· · III	76 through 200		


BUILDING CODES CITED:


1. National Fire Protection Association, ANSI/NFPA No. 101, "Life Safety Code", 1994 Edition.


2. Uniform Building Code, 1994 Edition, Chapter 8, Interior Finishes, Sections 801-807.




<text><text><text><text><text><text><text><text><text><text><text><text>







DIVERSIFIED



TESTING LABORATORIES, INC. WORLDWIDE SERVICE

336 WEST FRONT STREET P.O. BOX 4004 BURLINGTON, NORTH CAROLINA 27215 PHONE (336) 227-7710 • FAX (336) 227-1175 www.diversifiedtestinglabs.com

August 10, 2012

Ms. Tevan Riedel AMERICOVER 2067 Wineridge Place Suite F Escondido, CA 92029

Reference: Laboratory Test Report Lab Identification No. 3579 Invoice No. 34099 (Attached)

Dear Ms. Riedel:

One (1) sample, identified as **4 MIL BLACK FR B4**, was received and tested in accordance with the National Fire Prevention Association No. 701, "Standard Methods of Fire Tests for Flame Propagation of Textiles and Films, 2010 Edition, (Test 2, Large Scale)". The results are as follows:

Specimer	n Number	After Flame (seconds)	Residual Flame (seconds)	Char Length (inches)
Folds	1	0.0	0.0	18.0
	2	0.0	0.0	22.0
	3	0.0	0.0	20.0
	4	0.0	0.0	20.0

The sample submitted **meets** the minimum requirements of the above standard. The length of char on the individual folded specimens shall not exceed 41.3 inches. Additionally, no specimen shall continue flaming for more than two (2) seconds after the test flame is removed and no residues shall fall to the floor of the test chamber and continue flaming for more than two (2) seconds at any time during the test.

If there are any questions or when we can be of further assistance, please let us know.

Sincerely,

Bobby E. Puett

BEP/mr Attachment

OUR LETTERS AND REPORTS ARE FOR THE EXCLUSIVE USE OF THE CLIENT TO WHOM THEY ARE ADDRESSED. ANY COMMUNICATION TO OTHERS OR THE USE OF OUR COMPANY NAME MUST RECEIVE PRIOR APPROVAL, OUR TEST RESULTS APPLY ONLY TO THE SAMPLE TESTED AND ARE NOT NECESSARILY INDICATIVE OF THE QUALITIES OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS. SAMPLES NOT DESTROYED IN TESTING ARE RETAINED A MAXIMUM OF THIRTY DAYS. THE LETTERS, REPORTS OR NAME OF DIVERSIFIED TESTING LABORATORIES, INC. MAY NOT BE USED IN ADVERTISING TO THE GENERAL PUBLIC.

- "We Test Per Your Request"—

4 Mil Black Plastic Material Safety Data Sheet							
SECTION I							
MANUFACTURER'S NAME					EMERGENCY TE		
Americover Inc		800-747-0	6095				
ADDRESS (Number, Street, City, State and Zip Code) 2067 Wineridge Pl., Ste. FEscondido, C	CA 92	.029					
PRODUCT IDENTIFICATION	PRODUCT IDENTIFICATION USE/DESCRIPTION DATE OF MOST RECENT REVISION						
Fire Retardant 4 mil black polyethylene	Prote	ective Plast	tic Sheetir	ıg	1/18/06		
SECTION II - HAZARI	DOU	S INGR	EDIEN	FS/IDENTI	TY INFO	RMATIC	DN
HAZARDOUS COMPONENTS		CAS	NO.	ACGIH-TLV	ACGIH - ST	TEL	%
Not Applicable							
Not Applicable							
<u> </u>							
SECTION III - PI	HYS	ICAL/C			CTERIS	FICS	
BOILING POINT	N//	4	SPECIFIC GRA	VITY $(H_2O = 1)$.910925	5
VAPOR PRESSURE (mm Hg.)		•	MELTING POIN	NT			
(at 77°F)	N//	A					
VAPOR DENSITY (AIR = 1)	N/4	Δ	EVAPORATIO	N RATE (Butyl Acetate = 1)		N/A	
SOLUBILITY IN WATER	1 1/1					14/11	
N/A							
APPEARANCE AND ODOR							
Black polyethylene film 4 mils thick	c - no	odor					
SECTION IV - FIRE AND EXPLOSION HAZARD DATA							
FLASH POINT (Method Used)		I	FLAMMABLE LIM		LEL	UEL	
N/A N/A EXTINGUISHING MEDIA							
Water spray, dry chemical, CO2							
SPECIAL FIRE FIGHTING PROCEDURES Self contained breathing apparatus and protective clothing should be worn in fighting fire involving chemicals							
UNUSUAL FIRE AND EXPLOSION HAZARDS							
		F	PAGE (1)				

Information given herein is offered in good faith as accurate, but without guarantee. Conditions of use and suitability of the product for particular uses are beyond our control. All risks of use of the product are therefore assumed by the user and we expressly disclaim all warranties of every kind and nature, including warranties of merchantability and fitness for a particular purpose in respect to the use or suitability of the product. Nothing is intended as a recommendation for uses which infringe valid patents or as extending license under valid patents. Appropriate warnings and sale handling procedures should be provided to handlers and users.

SECTION V - REACTIVITY DATA									
STABILITY	UNSTABLE		CONDITIONS TO AVOID						
	STABLE	XX							
INCOMPATIBILITY (Materials to avoid) Oxidizing materials can cause a reaction									
	HAZARDOUS DECOMPOSITION OR BYPRODUCTS As with other organic materials, combustion will produce carbon dioxide and probably carbon monoxide.								
HAZARDOUS POLYMERIZATION			CONDITIONS TO AVOID						
	Will not occur								
	SECT	ION VI -	HEALTH HAZA	ARD DATA					
HEALTH HAZARDS									
CARCINOGENICITY			NTP?	IARC MONOGRAPHS?	OSHA REGULATED?				
SIGNS AND SYMPTOMS OF	OVEREXPOSURE								
N/A									
EMERGENCY AND FIRST A EYES:	ID PROCEDURES	SKIN:		SWALLOWED:					
	ct with hot plastic, cool noval of the adhering n		rial adhering to the skin a eatment of the burn.	as quickly as possible w	ith cold water. See				
	CTION VII - PR SE MATERIAL IS RELEASED OR S		IONS FOR SAFE	E HANDLING A	ND USE				
N/A	SE MATERIAL IS RELEASED OR S	PILLED							
WASTE DISPOSAL METHOI)								
		l, state and lo	ocal regulations regarding	g disposal.					
PRECAUTIONS TO BE TAKE	EN IN HANDLING AND STORING								
SECTION VIII - CONTROL MEASURES: For Use Where Significant Eye, Skin Or Inhalation Exposure Is Likely									
RESPIRATORY PROTECTION (Specify Type)									
VENTILATION LOCAL EXHAUST N/A			SPECIAL N/A						
	MECHANICAL (Genera N/A	al)		OTHER N/A					
protective gloves N/A			EYE PROTECTION N/A						
OTHER PROTECTIVE CLOT N/A	HING OR EQUIPMENT		•						
WORK/HYGIENIC PRACTIC	ES								
			PAGE (2)						